








Outlet Tester (120V - 3 Wire US)

TYPICAL 3-WIRE RECEPTACLE

For use on
110 - 125 VAC
circuits



INDICATOR	FAULT	REASON FOR WIRING FAULT
	Open Ground	Ground wire not connected
	Open Neutral	Neutral wire not connected
	Open Hot	Hot wire not connected
	Hot/Ground Reverse	Hot and ground wires reversed
	Hot/Neutral Reverse	Hot and neutral wires reversed
	Correct	Receptacle is wired correctly

 CLEAR

 RED

 ORANGE

WARNING!

- Equipment on the tested circuit should be unplugged to avoid erroneous readings.
- Not a comprehensive diagnostic instrument but a simple instrument to detect most common improper wiring conditions.
- Must be used by a qualified electrician.
- Will not indicate quality of ground.
- Will not detect 2 hot wires in circuit.
- Will not detect a combination of defects.
- Will not indicate reversal of grounded and grounding conductors.

Chauvin Arnoux®, Inc. d/b/a AEMC® Instruments

Foxborough, MA 02035 USA

(508) 698-2115 • (800) 343-1391

www.aemc.com

MADE IN TAIWAN